



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo No.: FSR/0125186210900019

Date : 31-08-2026

From :
Divisional Fire Officer
Murshidabad Division,
West Bengal Fire & Emergency Services

To :
SHYAMANGINI KUNDU COLLEGE OF EDUCATION
Plot No-12265,12266, JL.No-107, Mouza-Talibpur, Vill-Kaggram, PO-Salar, PS-Salar, Dist- Murshidabad, PIN-742401

Sub : Renewal of Fire Safety Certificate of an existing construction of G+2 storied Educational Building in the name and style of "SHYAMANGINI KUNDU COLLEGE OF EDUCATION" at the premises of , Plot No-12265,12266 ,JL No-107,Mouza-Talibpur,Vill-Khargram,PO-Khargram,PS-Salar,Dist-Murshidabad,Pin-742401.

This is in reference to your AIN 211912606300012532 dated 22-Aug-2026 regarding Renewal of Fire Safety Certificate of an existing construction of G+2 storied Educational Building in the name and style of "SHYAMANGINI KUNDU COLLEGE OF EDUCATION" at the premises of , Plot No-12265,12266 ,JL No-107,Mouza-Talibpur,Vill-Khargram,PO-Khargram,PS-Salar,Dist-Murshidabad,Pin-742401..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

All the Fire Safety Recommendations which was issued vide this Office Memo No. IND/WB/FES/20192020/76418, Dated: - 13/01/2020 should be followed strictly at all time.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012532

2. Driveway must have to be kept free of obstruction at all time for EASY movement of fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in wear and tear in them, particularly lines above false ceiling & ducts.
6. A fire control room including a close circuit T.V. / Monitor system will have to be installed which will observe all the floor of the Building.
7. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at a venerable places of the Building.
8. The Employees and security staff shall be well conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
10. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
13. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of abovementioned system.
15. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
16. Transformer & switch Gear room (if applicable) shall be protected with CO2 or D.C.P. Fire Extinguisher conforming I.S. Specification.
17. This Fire Safety Certificate is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Divisional Fire Officer, Murshidabad Division, West Bengal Fire & Emergency Services regarding the Performance of all the Fire & life Safety arrangements and installation of the Building.
18. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated as cancelled automatically.

Valid Upto : 29-Aug-2029



Signature valid

Digitally Signed.
Name: Anirjit Ghosh
Date: 31-Aug-2023 19:48:21
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012532